WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41814
Permit No.
Basin 102

NOTICE OF INTENT NO. 23987

1. OWNER Jim Bashi
MAILING ADDRESS 1325 E. 6 Th. ST. Silver Springs, Nv. 89429
ADDRESS AT WELL LOCATION 1325 E. 6 Th. Silver Springs, Nv. 89429

2. LOCATION SE ¼ NW ¼ Sec. 18 T. 17 N/S R. 25 E. Lyon County
PERMIT NO. — (Issued by Water Resources) 17-274-02 (Parcel No.) Tyler Sub # 1 (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Surface Soil		0	4	4
Fine Brown Sand		4	17	13
Fine To corse Brown sand		17	40	23
Fine To corse gray Sand		40	115	75
gray clay		115	120	5
corse Sand & gravel	X	120	150	30

'93 JUN -8 A10:12
RECEIVED
STATE ENGINEERS OFFICE

Date started 6-1, 1993
Date completed 6-4, 1993

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
18	3	2 Hrs.

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11" Inches	0 Feet	150 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	150

Perforations:
Type perforation Mill
Size perforation 3/32 X 3
From 130 feet to 150 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 150 feet

9. WATER LEVEL
Static water level 37 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name ACE Drilling & Development (Contractor)
Address P.O. Box 668 (Contractor)
Silver Springs, Nvada 89429
Nevada contractor's license number issued by the State Contractor's Board 14299
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 726
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 6-7-1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627