WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 41830
Permit No.
Basin 104

NOTICE OF INTENT NO. 24247

1. OWNER Ed Barrington
MAILING ADDRESS Box 1203 Carson City Nv.
ADDRESS AT WELL LOCATION 4180 James Carson City Nv.

2. LOCATION NW SW ¼ NW ¼ Sec. 5 T. 15 N/S R. 20 E. Carson County
PERMIT NO. Issued by Water Resources | Parcel No. 8-111-08 | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0'	10	10'
Sand		10	45	35'
Y/4 Gravels		45	60	15'
Brown Sandy Clay		60	95	35'
Brown Clays w/gravels		95	110	15'
Soft Sand		110	130	20'
Brown gummy Clay		130	145	15'
D.G. Sands + Gravels	xxx	145	160	15'

MAY 21 '93 AM 10:55 STATE ENGINEER'S OFFICE

Date started 5/4, 1993
Date completed 5/6, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
10	80'	2½

8. WELL CONSTRUCTION
Depth Drilled 160' Feet Depth Cased 160' Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
11¼"	0	55'
10"	55	160

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.03	.188	0	160

Perforations:
Type perforation Mill Slot
Size perforation 3 X 3/32
From feet to feet
From 140' feet to 160' feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 55
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 55' feet to 160' feet

9. WATER LEVEL
Static water level 20' feet below land surface
Artesian flow G.P.M. 10 P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name A & H PUMP CO. Contractor
Address 5551 Hwy. 50 East Carson City, Nevada 89706 Contractor
883-0459 885-1865
Nevada contractor's license number issued by the State Contractor's Board 31839
Nevada driller's license number issued by the Division of Water Resources, the on site driller 1674
Signed Joe Bulto
By driller performing actual drilling on site or contractor
Date 5/10/93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627