

LOG # 41845
 OFFICE USE ONLY
 Log No. 4405
 Permit No. 57539-57540
 Basin 105-CARSON V.

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18470
 None

1. OWNER Doug Lippincott ADDRESS AT WELL LOCATION None
 MAILING ADDRESS 5035 Ponderosa
Carson City, Nv.
 2. LOCATION SW $\frac{1}{4}$ NW $\frac{1}{4}$ Sec. 30 T. 14 N/S R20 E Douglas County
 PERMIT NO. 57539 / 57540 Parcel No. 15-060-29 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy clay		0	11	11
Fine Sand	xxx	11	18	7
Decomposed Granite		18	115	97
Blue Clay		115	125	10
Decomposed Granite with interbedded granite rocks and boulders some sign of altering to clay		125	400	

8. WELL CONSTRUCTION
 Depth Drilled 400 Feet Depth Cased 400 Feet
 HOLE DIAMETER (BIT SIZE)
 From 20 Inches 0 Feet 400 Feet
 To 400 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
12 3/4		.250	0	400

Perforations:
 Type perforation Mill Cuts
 Size perforation 3/16 x 2 1/2
 From 100 feet to 400 feet
 From 100 feet to 400 feet
 From 100 feet to 400 feet
 From 100 feet to 400 feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal 100
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 100 feet to 400 feet

9. WATER LEVEL
 Static water level 0 feet below land surface
 Artesian flow 800 G.P.M. unknown P.S.I.
 Water temperature cool °F Quality unknown

Date started 10 / 22, 1992
 Date completed 6 / 6, 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>1500</u>	<u>unknown</u>	<u>2 hrs.</u>

8" water meter installed on flow line. 6/11/93

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Oasis Drilling Inc. Contractor
 Address Po. Box 21421 Contractor
Carson City Nevada
 Nevada contractor's license number issued by the State Contractor's Board 0023129
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1386
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 6/11 / 93