WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42050
Permit No.
Basin 8-103

NOTICE OF INTENT NO. 10017

1. OWNER Gene Sacaone Prop.
MAILING ADDRESS 6195 Shetland
State Coach NV. 89429

ADDRESS AT WELL LOCATION 6195 Shetland
State Coach NV

2. LOCATION NE ¼ NW ¼ Sec. 11 T. 17 N/S R. 23 E. Lyon County
PERMIT NO. NA (Issued by Water Resources) 19-382-36 (Parcel No.) Rancho # 2 (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☑ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil and Brown Clay		0	42	42
Clay Brown		42	85	43
Course Sand And Some Clay		85	95	10
Boulders and Some Gravels	✓	95	120	25
Gravels	✓	120	130	10

JUL 21 '93 AM 10:58 STATE ENGINEER'S OFFICE

Date started 6/30, 1993
Date completed 7/1/93, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Developed For 3 Hours and Produced about 10 Gallons a min		

8. WELL CONSTRUCTION
Depth Drilled 130 Feet Depth Cased 130 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
11" Inches	0 Feet	130 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.00	3/16	+1	130

Perforations:
Type perforation AIR PerF
Size perforation
From 100 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 60 feet to 130 feet

9. WATER LEVEL
Static water level 68 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc (Contractor)
Address PO Box 599 (Contractor)
Silver Springs NV 89429
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on site driller 1877
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 7-15-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627