

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 20374

1. OWNER Ron Scandrett ADDRESS AT WELL LOCATION 3 Pinon Drive
 MAILING ADDRESS _____
 2. LOCATION NW 1/4 SW 1/4 Sec. 10 T. 11 N/S R. 23 E. Lyon County
 PERMIT NO. APR 09 052 20 Parcel No. _____ Subdivision Name Valley View Ranch
 Issued by Water Resources _____

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Municipal/Industrial Irrigation Monitor Test Stock
 5. WELL TYPE Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SAND - DG		0	25	
DG SOME SANDY CLAY		25	47	
SANDY BRN CLAY W DG		47	56	
DG SOME SANDY BRN CLAY		56	115	
DG CEMENTED		115	134	
DG SOME SANDY BRN CLAY	WB	134	160	
DG SOME SANDY BRN CLAY		160	220	
DG W SANDY BRN CLAY	WB	220	250	
DG CEMENTED W/FRACT	WB	250	260	

8. WELL CONSTRUCTION
 Depth Drilled 260 Feet Depth Cased 260 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
9 1/8" Inches 0 Feet 260 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>		<u>188"</u>	<u>0</u>	<u>260</u>

Perforations:
 Type perforation FACTORY
 Size perforation 3/32" x 3"
 From 260 feet to 240 feet
 From 240 feet to 220 feet T.C.
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 260 feet to 50 feet

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. 35+ P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ED MILLER Contractor
 Address Box 92 Contractor SMITH, NV 89444
 Nevada contractor's license number 32164 issued by the State Contractor's Board.
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
 Signed Sergie P. Russell
 By driller performing actual drilling on site or contractor
 Date 6-12-93

Date started 6-9 1993
 Date completed 6-14 1993

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>35+</u>		<u>8</u>	