

OFFICE USE ONLY
 Log No. 42081
 Permit No. 9-1081
 Basin 9-1081

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16620

1. OWNER Norman Pursel ADDRESS AT WELL LOCATION 11 Pursel Lane
 MAILING ADDRESS P.O. Box 106 Yerington Nev 89447
 2. LOCATION NW 1/4 NE 1/4 Sec. 2, T. 12, R. 25 E. Lyon County
 PERMIT NO. 12-141-07 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition Domestic
 Deepen Abandon Other
 Municipal/Industrial Irrigation Test Cable Rotary RVC
 Monitor Stock Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Coarse Sand + Gravel		0	5	5
Brown Clay		5	18	13
Coarse Sand + Gravel + Small Rock		18	78	60
Coarse Sand + Rock		28	96	18
Coarse Sand + Gravel + Small Rock		96	112	16
Coarse Sand + Gravel + Clay		112	125	13
Coarse Sand + Gravel + Small Rocks		125	142	17
Coarse Sand + Gravel	X	142	158	16
Coarse Sand + Gravel + Rock		158	160	2

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 161 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 3/8 Inches To 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 7/8</u>	<u>12.92</u>	<u>.188</u>	<u>+1</u>	<u>160</u>

Perforations:
 Type perforation Sawed
 Size perforation 3/32 x 3" x 6 Rows
 From 140 feet to 160 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 100 feet to 160 feet

9. WATER LEVEL
 Static water level 62 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Ogden Bros Drilling Contractor
 Address 162 N. ByBee Lane Contractor
Yerington Nev 89447
 Nevada contractor's license number issued by the State Contractor's Board 15646
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 634
 Signed Har Ogden
 By driller performing actual drilling on site or contractor
 Date 6-28-93

Date started Sept 2, 1992
 Date completed Sept 8, 1992

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input checked="" type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
<u>Bailer</u>	<u>2.35</u>	<u>3</u>	<u>1/2</u>

JUN 29 P1:30
 STATE ENGINEERS OFFICE