WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42167
Permit No.
Basin 8-101

NOTICE OF INTENT NO. 19130

1. OWNER Mack Rose
MAILING ADDRESS 2695 Rogers RD. Fallon NV
ADDRESS AT WELL LOCATION 2434 Testoline Fallon NV

2. LOCATION SE ¼ NE ¼ Sec. 5 T. 18 ☐S R. 29 E. Churchill County
PERMIT NO. Issued by Water Resources
Parcel No. 06-671-05
Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☑ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Soil	NO	0	2	2
Sand clay	NO	2	7	5
heaving sand	yes	7	10	3
Clay (Brown)	NO	10	15	5
Sand	yes	15	17	2
light brn clay	NO	17	23	6
Sand	yes	23	29	6
Black sand - gravel	yes	29	30	1
brn clay	NO	30	32	2
will Pull	Casing + clean			
will install	25'	Seal		

JUN -4 A11:14 '93
STATE ENGINEER'S OFFICE

Date started 5/14, 1993
Date completed 5/14, 1993

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
12	5	1

8. WELL CONSTRUCTION
Depth Drilled 32 Feet Depth Cased 32 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10	0	32

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6		188	0	32

Perforations:
Type perforation torch cut
Size perforation 1/16 x 4"
From 20 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 15
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☑ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 15 feet to 32 feet

9. WATER LEVEL
Static water level 8 feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature 60.10 °F Quality FAIR

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Ed Miller Contractor
Address P.O. 92 Contractor
SMITH, NV 89430
Nevada contractor's license number issued by the State Contractor's Board 32166
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1006
Signed (By driller performing actual drilling on site or contractor)
Date 5/16/93

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(10) 627