WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42171
Permit No.
Basin 101

NOTICE OF INTENT NO. 24055

1. OWNER Help-U-Sell Realty
MAILING ADDRESS 710 W. Williams Avenue, Fallon, NV 89406
ADDRESS AT WELL LOCATION 2980 Peachtree Rd., Fallon, NV 89406

2. LOCATION SW ¼ SW ¼ Sec. 6 T. 18 N/X R. 29 E. Churchill County
PERMIT NO. (Issued by Water Resources) 006-741-27 (Parcel No.) Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand		0	12	12
Brown Clay		12	18	6
Brown Fine Sand		18	20	2
Brown Coarse Sand		20	22	2
Green Clay		22	24	2
Fine Brown Sand		24	28	4
Brown Coarse & Fine Sand	X	28	31	3

Date started May 25, 19 93
Date completed May 25, 19 93

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 31 Feet Depth Cased 31 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	31 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	31

Perforations:
Type perforation Mill Cut
Size perforation 1/8"
From 28 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 25
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 25 feet to 31 feet

9. WATER LEVEL
Static water level 6 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Parsons Drilling, INc. (Contractor)
Address P.O. Box 1265 (Contractor)
Fallon, NV 89407-1265
Nevada contractor's license number issued by the State Contractor's Board 29064
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1715
Signed Doug Parsons (By driller performing actual drilling on site or contractor)
Date June 1, 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627