WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42808
Permit No.
Basin B-102

NOTICE OF INTENT NO. 20426

1. OWNER Tenaya Investment Co
MAILING ADDRESS PO. 279 Verdi Nevada.
ADDRESS AT WELL LOCATION 2925 Ramsey Cut Off. Silver Springs NV. 89429

2. LOCATION SW ¼ SW ¼ Sec. 35 T. 18 N/S R. 24 E Lyon County
PERMIT NO. NA Issued by Water Resources
Parcel No. #7 15-24-35
Subdivision Name Tenaya-Lumos

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravels and Soil		0	40	40
Clay and Some Gravel		40	45	05
Some Gravel and Clay		45	55	10
Gravel and Some Clay		55	75	20
Clay		75	130	50
Clay with some Rock		130	167	37
Clay		167	200	33
Blue Hard Clay		200	310	110
Red and Brown Broken Slate		310	340	30
Gray Clay		340	383	43
Gray clay with Some Fine Rock		383	440	
Black Slate		440	460	

Date started 6-21-93, 1995
Date completed 6-28-93, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Developed For 3 Hours Produced about 25 Gallons a min		

8. WELL CONSTRUCTION
Depth Drilled 460 Feet Depth Cased 460 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
11"	Inches	0 Feet	120 Feet
6 3/4	Inches	120 Feet	340 Feet
6 1/8	Inches	340 Feet	460 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	15.00	3/16 .188	+1	340
4 1/2	11.00	.250	340	460

Perforations:
Type perforation
Size perforation
From 300 feet to 340 feet
From 440 feet to 460 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 340 feet

9. WATER LEVEL
Static water level 175 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Tech Drilling Inc Contractor
Address PO Box 599 Silver Springs NV 89429 Contractor
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1873
Signed [signature] By driller performing actual drilling on site or contractor
Date

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O)-627