



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 12053

1. OWNER Vera Wilson ADDRESS AT WELL LOCATION Lot 6 Dickman & Bridger St
 MAILING ADDRESS _____

2. LOCATION NE 1/4 SE 1/4 Sec 14 T 21S N/S R 53 E NYC County _____
 PERMIT NO. 44-661-09 Parcel No. _____ Subdivision Name LAS CASITAS Ranchos

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Clay		0	8	8
Caliche		8	10	2
Clay		10	24	14
Caliche		24	27	3
Clay		27	37	10
Caliche		37	39	2
Clay		39	50	11
Caliche		50	55	5
Clay		55	77	22
Caliche	WB	77	79	2
Clay		79	88	9
Caliche	WB	88	96	8
Clay		96	110	14
Caliche	WB	116	123	13
Clay		123	126	3
Caliche	WB	126	131	5
Clay		131	137	6
Caliche	WB	137	140	3

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
 From 12 1/4 Inches 6 Feet 140 Feet
 To _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.44</u>	<u>.184</u>	<u>0</u>	<u>140</u>

Perforations:
 Type perforation Factory Saw cut
 Size perforation 1/8 x 3/32
 From 100 feet to 120 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 54 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Great Basin Drilling Contractor
 Address HR 78 Box 80358 R Contractor
Abamp NV 89041
 Nevada contractor's license number 30880 issued by the State Contractor's Board
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
 Signed Thomas Dan
 By driller performing actual drilling on site or contractor
 Date 8/2/93

Date started 7-28 1993
 Date completed 7-30 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
 AUG 10 1993
 Div. of Water Resources
 Branch Office - Las Vegas, NV