

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.34



Log No. 42370  
 Permit No.  
 Basin  
 NOTICE OF INTENT NO. 11671

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

1. OWNER JERRY BRUNNER ADDRESS AT WELL LOCATION HALEY + RIO VISTA  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION SW 1/4 NE 1/4 Sec 22 T. 19 N/S R. 60 E CLARK County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
ROCKS + CLAY		0	10	10
CLAY W/ STRKS		10	30	20
CALICHE				
CLAY + GRAVEL		30	100	70
BROWN LIME		100	115	15
CLAY + GRAVEL		115	150	35
BROWN LIME		150	160	10
CLAY + GRAVEL		160	500	340
W/ STRKS POPCORN				
CALICHE				

8. WELL CONSTRUCTION  
 Depth Drilled 500 Feet Depth Cased 500 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches To 0 Feet 500 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	+1	500

Perforations:  
 Type perforation FACTORY SAW  
 Size perforation 18 x 3/12  
 From 456 feet to 480 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 500 feet

RECEIVED  
 SEP 8 1993  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 8-28 1993  
 Date completed 8-31 1993

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL  
 Static water level \_\_\_\_\_ feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name DESERT DRILLING Contractor  
 Address 6475 GARY AVE  
LAS VEGAS, NV. 89139  
 Nevada contractor's license number issued by the State Contractor's Board 34274  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1594  
 Signed Imdale Coull  
 By driller performing actual drilling on site or contractor  
 Date 8-31-93