WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42441
Permit No.
Basin 6-84

NOTICE OF INTENT NO. 21861

1. OWNER HOWARD & LAURA WAGNER
MAILING ADDRESS P.O. BOX 10383
RENO, NV 89510

ADDRESS AT WELL LOCATION 6055 Easy Jet Road
Reno, NV 89510

2. LOCATION SE ¼ NW ¼ Sec. 31 T ~~28N~~ 23 N/S R. 21 E. Washoe County
PERMIT NO. (Issued by Water Resources) 076-231-10 (Parcel No.) Palomino Valley (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [X] Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown sandy clay		1	38	37
Brown sand		38	41	3
Brown clay		41	48	7
Fine brown sandy clay		48	68	20
Brown clay		68	111	43
Fine brown sandy clay		111	168	57
Brown clay		168	193	25
Coarse sands	X	193	210	17
Brown clay		210	231	21
Coarse sands	X	231	260	29
Fine silty brown clay		260	265	5

Date started 7-12-93, 19
Date completed 7-16-93, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 265 Feet Depth Cased 265 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	265 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	265

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 179 feet to 219 feet
From 239 feet to 259 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 265 feet

9. WATER LEVEL
Static water level 53 feet below land surface
Artesian flow 60+ G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date July 19, 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627