

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 42504
 Permit No. _____
 Basin 8-101

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24123

1. OWNER Budge Brown ADDRESS AT WELL LOCATION Eagle Ranch
 MAILING ADDRESS 844 East Woodward 12241 Pioneer Way
Manteca, CA 95336 Fallon, NV

2. LOCATION NE 1/4 SE 1/4 Sec. 29 T 19 N 27 E Churchill County
 PERMIT NO. 48420 & 48421 NA NA
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thick-ness |
|--------------------------------|--------------|------|-----|------------|
| Sand & gravel | | 0 | 13 | 13 |
| Clay | | 13 | 38 | 25 |
| Sand | X | 38 | 53 | 15 |
| Gray clay | | 53 | 81 | 28 |
| Clay w/sand & gravel stringers | X | 81 | 106 | 25 |
| Gravel & cobbles | X | 106 | 160 | 54 |
| Clay | | 160 | 163 | 3 |
| Sand | X | 163 | 180 | 17 |
| Sand & gravel | X | 180 | 215 | 35 |
| Sandy clay | | 215 | 225 | 10 |
| Sand/gravel/cobbles | X | 225 | 268 | 43 |
| Brown sandy clay | | 268 | 275 | 7 |
| Sand/gravel/cobbles | X | 275 | 295 | 20 |
| Light brown clay | | 295 | 315 | 20 |
| Sand | X | 315 | 323 | 8 |
| Clay | | 323 | 335 | 12 |
| Sand | X | 335 | 339 | 4 |
| Clay | | 339 | 345 | 6 |

8. WELL CONSTRUCTION
 Depth Drilled 345 Feet Depth Cased 340 Feet

HOLE DIAMETER (BIT SIZE)
 From To
42 Inches 0 Feet 13 Feet
36 Inches 0 Feet 50 Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|--------------------|---------------------|-------------------------|-------------|-----------|
| 16 | 42.05 | .250 | 0 | 100 |
| 16 | 42.05 | .250 | 100 | 340 |

Perforations:
 Type perforation Mill Slot
 Size perforation 5/32
 From 100 feet to 340 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Cement Grout
 Concrete Grout
 Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From 50 feet to 345 feet

Date started July 20, 1993
 Date completed July 24, 1993

7. WELL TEST DATA

| TEST METHOD: | G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|--|-------------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift | <u>3000</u> | <u>138.4</u> | <u>8</u> |
| *Pumping level <u>178'</u> | | | |

9. WATER LEVEL
 Static water level 39.6 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Humboldt Drilling & Pump Co., Inc. Contractor
 Address P.O. Box 590 Contractor
Winnemucca, NV 89446
 Nevada contractor's license number issued by the State Contractor's Board 015234
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1562
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date 8-8-93

RECEIVED
 STATE ENGINEERS OFFICE
 1993 SEP -2 AM 1:31