

OFFICE USE ONLY

Log No. 42565
 Permit No. _____
 Basin 9-106

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18962

1. OWNER MEL SPANIOLO ADDRESS AT WELL LOCATION 1386 Hwy 395, South
 MAILING ADDRESS 1247 BUENA VISTA ST
SPAN JACINTO CAL 92583

2. LOCATION SE 1/4 S.W. 1/4 Sec. 7 T. 10 N/S R. 22 E DOG LIPS County
 PERMIT NO. APN 3211009 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Alluvial</u>				
<u>Broken Rock & Dirt</u>	<u>no</u>	<u>0</u>	<u>45'</u>	<u>45'</u>
<u>Cemented gravel</u>	<u>no</u>	<u>45'</u>	<u>105'</u>	<u>60'</u>
<u>Washed Gravel</u>	<u>no</u>	<u>105'</u>	<u>125'</u>	<u>20'</u>
<u>gravel & clay layered</u>	<u>no</u>	<u>125'</u>	<u>145'</u>	<u>20'</u>
<u>washed gravel</u>	<u>yes</u>	<u>145'</u>	<u>162'</u>	<u>17'</u>
<u>AAAD lens</u>				
<u>Superior</u>	<u>no</u>	<u>162'</u>	<u>170'</u>	<u>8'</u>
<u>fractured rock</u>				
<u>in some gravel lenses</u>	<u>yes</u>	<u>170'</u>	<u>195'</u>	<u>25'</u>

8. WELL CONSTRUCTION
 Depth Drilled 195 Feet Depth Cased 195 Feet

HOLE DIAMETER (BIT SIZE)
 From 9 7/8 Inches To 8 Feet
 From 8 Feet To 195 Feet
 From _____ Inches To _____ Feet
 From _____ Inches To _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>	<u>17</u>	<u>3/16</u>	<u>0</u>	<u>195</u>

Perforations:
 Type perforation fact saw slot
 Size perforation 3/32
 From 175 feet to 195 feet
 From 135 feet to 135 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50
 Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 50 feet to 190 feet

9. WATER LEVEL
 Static water level 98 feet below land surface
 Artesian flow NA G.P.M. NA P.S.I.
 Water temperature COLD °F Quality GOOD

Date started 8-30 1993
 Date completed 9-4 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailor <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>	<u>NA</u>	<u>7 1/2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name ED MILLER Contractor
 Address PO Box 92, SPALDING NV 89444 Contractor

Nevada contractor's license number issued by the State Contractor's Board 32166
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1533

Signed Scott Caldwell
 By driller performing actual drilling on site or contractor
 Date 9/1/93