58177

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42590
Permit No. 50053
Basin 2-28

NOTICE OF INTENT NO. 11467

1. OWNER Lawrence Montero
MAILING ADDRESS St. Rt. #390
Winnemucca, NV 89445

ADDRESS AT WELL LOCATION Leonard Creek Ranch - 60 miles N. Winnemucca, NV At Ranch

2. LOCATION NE ¼ SW ¼ Sec. 1 T. 41 N/S R. 28 E. Humboldt County

PERMIT NO. NWL2060NW 58177 (Issued by Water Resources) | Parcel No. | N/A (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☒ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Topsoil		0	6	
Clay		6	30	
Sand + Gravel		30	58	
Clay		58	93	
Sand + Gravel		93	116	
Clay		116	127	
Sand + Gravel		127	152	
Clay		152	155	

Replacement of log # 22406

'93 JUN 25 A10:30
STATE ENGINEER'S OFFICE

Date started 11/13, 1992
Date completed 11/16, 1992

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 155 Feet Depth Cased 155 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10.625 Inches	0 Feet	155 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6.625	10	.188	0	

Perforations:
Type perforation Mill slot
Size perforation 3/32
From 125' feet to 155' feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50'
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50' feet to 155 feet

9. WATER LEVEL
Static water level 80' feet below land surface
Artesian flow No G.P.M. 30 P.S.I.
Water temperature Cool °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Fred S. Anderson (Contractor)
Address 10760 Grass Vly Rd (Contractor)
Winnemucca, NV 89445
Nevada contractor's license number issued by the State Contractor's Board 21467
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1375
Signed [signature] By driller performing actual drilling on site or contractor
Date November 21, 1992

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627