

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 42606  
 Permit No. 4-45  
 Basin 4-45

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 10025

1. OWNER SONNIE Milano ADDRESS AT WELL LOCATION Lot 3  
 MAILING ADDRESS 193-2 PLEASANT VALLEY 146 CROW BAR LANE PLEASANT VALLEY

2. LOCATION SW 1/4 NW 1/4 Sec 26 T 33 S R 57 E ELKO County  
 PERMIT NO. 23-005-C3-6 PLEASANT VALLEY Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

| Material         | Water Strata | From | To  | Thick-ness |
|------------------|--------------|------|-----|------------|
| Sub soil         |              | 0'   | 1'  | 1          |
| Gravel           |              | 1    | 15  | 14         |
| Decompose Gannet |              | 15   | 72  |            |
| CLAY             |              | 72   | 80  | 6          |
| Hard Gannet      |              | 80   | 82  |            |
| Loose Gravel     | ✓            | 82   | 87  | 5          |
| CLAY             |              | 87   | 89  | 2          |
| Hard Gannet      |              | 89   | 90  | 1          |
| CLAY             |              | 90   | 100 | 10         |
| Hard Gannet      |              | 100  | 107 | 7          |
| Loose Gravel     | ✓            | 107  | 108 | 1          |
| CLAY             |              | 108  | 148 | 40         |
| Loose Gravel     | ✓            | 148  | 162 | 14         |

8. WELL CONSTRUCTION  
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)  
 From To  
10" Inches 0 Feet 160 Feet  
 Inches Feet Feet  
 Inches Feet Feet

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet)  |
|--------------------|---------------------|-------------------------|-------------|------------|
| <u>6"</u>          | <u>12.92</u>        | <u>1.88</u>             | <u>12</u>   | <u>160</u> |

Perforations:  
 Type perforation Slots  
 Size perforation 3/16" X 3"  
 From 135 feet to 160 feet  
 From.....feet to.....feet  
 From.....feet to.....feet  
 From.....feet to.....feet  
 From.....feet to.....feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 0-60  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 60 feet to 160 feet

9. WATER LEVEL  
 Static water level 96 feet below land surface  
 Artesian flow.....G.P.M.....P.S.I.  
 Water temperature Cold °F Quality Good

Date started 6-24, 19 93  
 Date completed 7-15, 19 93

7. WELL TEST DATA

| TEST METHOD:   | G.P.M.    | Draw Down (Feet Below Static) | Time (Hours) |
|--|-----------|-------------------------------|--------------|
| <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift | <u>38</u> |                               | <u>4</u>     |

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name FERTIG Drilling Co Contractor  
 Address PO Box 525 Contractor  
ELKO NV 89803  
 Nevada contractor's license number issued by the State Contractor's Board 31904  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1584  
 Signed Shane C. Fritzsche  
 By driller performing actual drilling on site or contractor  
 Date 8-7-93