WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42739
Permit No.
Basin 6-89

NOTICE OF INTENT NO. 21848

1. OWNER EDDIE & TERRI MENGHINI
MAILING ADDRESS 4075 Drake Way
Carson City, NV 89704

ADDRESS AT WELL LOCATION 395 McClellan
Carson City, NV 89704

2. LOCATION SW ¼ NE ¼ Sec. 32 T. 17N N/S R. 20 E. Washoe County
PERMIT NO. (Issued by Water Resources) 050-371-28 (Parcel No.) Washoe Valley (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown fine sand		0	7	7
Decomposed granite with some granite boulders		7	11	4
Weathered granite		11	73	62
White granite		73	109	36
Fracture (NO WATER)		109	110	1
White granite		110	133	23
WEathered granite		133	172	39
White granite		172	273	101
Fracture	X	273	274	1
White granite		274	309	35
Fracture	X	309	310	1
White granite		310	334	24
Fracture	X	334	335	1
White granite		335	350	15

'93 SEP 30 AM 10:47
STATE ENGINEER'S OFFICE

Date started 9-7-93, 19
Date completed 9-15-93, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 350 Feet Depth Cased 350 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	350 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	350

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 265 feet to 275 feet
From 295 feet to 305 feet
From 325 feet to 345 feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout
Gravel Packed: [X] Yes [ ] No
From 50 feet to 350 feet

9. WATER LEVEL
Static water level 171 feet below land surface
Artesian flow 18 G.P.M. P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date September 22, 1993

(Rev. 3 91)
USE ADDITIONAL SHEETS IF NECESSARY
(O)-627