WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42770
Permit No.
Basin 8-103

NOTICE OF INTENT NO. 20419

1. OWNER Gene Saccone
MAILING ADDRESS 6135 Shetland
Stage Coach NV 89429

ADDRESS AT WELL LOCATION 6135 Shetland.
Stage Coach NV

2. LOCATION NE ¼ NW ¼ Sec. 11 T. 17 N/S R. 23 E. Lyon County
PERMIT NO. NA (Issued by Water Resources) | Parcel No. 19-382-34 | Subdivision Name Rancho Sub #2

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☑ Other mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand and Gravel		0	30	30
Boulders and Gravels		30	65	35
Fine Gravels and some Course Gravels		65	85	20
Brown Clay		85	95	10
Fine and Course Gravels		95	105	10
Tan Clay		105	110	5
Fine Sand and Course Gravels		110	130	20

Date started 8-27-93
Date completed 8-28-93

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Developed for 3 hrs. and produced about 15 Gallons a min.		

8. WELL CONSTRUCTION
Depth Drilled 130 Feet Depth Cased 131 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	130 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.00	3/16	+1	130

Perforations:
Type perforation Air Perf
Size perforation ¼ x 1 x 20 ft 5 Rows
From 100 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-60
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 60 feet to 130 feet

9. WATER LEVEL
Static water level 55 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Tech Drilling Inc (Contractor)
Address PO Box 579 Silver Springs NV 89429 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 0031841
Nevada driller's license number issued by the Division of Water Resources, the on site driller 1877
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 8-28-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627

STATE ENGINEERS OFF. '93 SEP 29 A11:00