WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

**Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340**

OFFICE USE ONLY
Log No. 42841
Permit No.
Basin 4-69

NOTICE OF INTENT NO. 20482

1. OWNER Gary Echevarria
MAILING ADDRESS P.O. Box 95
Winnemucca, NV 89446

ADDRESS AT WELL LOCATION
Not assigned at this time

2. LOCATION SE ¼ NW ¼ Sec. 25 T. 42 N/S R. 39 E. Humboldt County
PERMIT NO. "NA" (Issued by Water Resources) | 4/Blk.G (Parcel No.) | NONE (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Clay | | 0 | 10 | |
| Clay & Sand | | 10 | 15 | |
| Decomposed Granite | | 15 | 35 | |
| Rock | | 35 | 45 | |
| Clay & Rock | | 45 | 75 | |
| Clay | | 75 | 100 | |
| Clay w/s stringers gravel | | 100 | 140 | |

'93 OCT 13 P2:36
STATE ENGINEER'S OFFICE

Date started September 26, 19 93
Date completed September 29, 19 93

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 25 | | 5 Hrs. |

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 10 Inches | | 0 Feet | 140 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 6 5/8 | | .188 | | |

Perforations:
Type perforation 1/8X 2 1/2
Size perforation
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100 Ft.
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 140 feet

9. WATER LEVEL
Static water level 15 Ft. feet below land surface
Artesian flow NONE G.P.M. NONE P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Dave McNinch (Contractor)
Address P.O. Box 585 (Contractor)
Winnemucca, NV 89446
Nevada contractor's license number issued by the State Contractor's Board 5437
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 730
Signed Gerald Lee Mowry (By driller performing actual drilling on site or contractor)
Date October 8, 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627