WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42898
Permit No.
Basin 4-71

NOTICE OF INTENT NO. 18229

1. OWNER David Hardin
MAILING ADDRESS 8745 S. Ryan
Winnemucca, NV 89445

ADDRESS AT WELL LOCATION 9845 Alice Winnemucca

2. LOCATION SE ¼ SW ¼ Sec 30 T 35 N/S R 38 E Humboldt County
PERMIT NO. - (Issued by Water Resources) 010 543-04 (Parcel No.) ZBS Lot 57 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand/clay		0	6	6
Gravel		6	38	32
Brown clay		38	50	12
Green rock		50	58	8
Clay		58	65	7
Gravel		65	78	13
Clay		78	86	8
Basalt		86	88	2
Gravel		88	93	5
Basalt		93	135	42
Clay		135	143	8
Basalt		143	150	7
Sand		150	151	1
Basalt		151	155	4
Rock/sand stringers		155	180	25
Sand/gravel		180	203	23
Boulders		203	205	2
Sand/gravel		205	211	6
Sandy clay		211	215	4
Sandy clay		215	240	25

Date started September 28, 19 93
Date completed September 30, 19 93

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30		air on rig

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 230 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
9 7/8	Inches	0	Feet	230	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6		.250	+2	140

Perforations:
Type perforation Cutters knife
Size perforation 1/8 X 2
From 140 feet to 230 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 240 feet

9. WATER LEVEL
Static water level 120 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address P.O. Box 590 (Contractor)
Winnemucca, NV 89446
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller T-1195-1
Signed C. E. Epler (By driller performing actual drilling on site or contractor)
Date 10-13-93

(Rev. 3-91)

USE ADDITIONAL SHEETS IF NECESSARY

(O) 627