WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42912
Permit No.
Basin 6-85

NOTICE OF INTENT NO. 25219

1. OWNER Randy Hale
MAILING ADDRESS P.O. Box 18404 Reno, Nev 89511
ADDRESS AT WELL LOCATION 1525 Bonanza Virginia City, Nv

2. LOCATION SE ¼ NE ¼ Sec. 5 T. 17 N/S R. 21 E. Storey County
PERMIT NO. (Issued by Water Resources) 03-162-11 (Parcel No.) VC Highlands Estates (Subdivision Name)

3. WORK PERFORMED: [X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE: [X] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE: [ ] Cable [ ] Rotary [ ] RVC [X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Black Rock		0	30	30
Yellow Clay stone		30	80	50
Blue Shale Stone		80	143	63
	110			
	125			

RECEIVED 93 OCT 28 A10:36 STATE ENGINEERS OFFICE

Date started Oct 9, 1993
Date completed Oct 9, 1993

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		1

8. WELL CONSTRUCTION
Depth Drilled 143 Feet Depth Cased 143 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	50 Feet
8 3/4 Inches		50 Feet	143 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	+1	143

Perforations:
Type perforation Factory Milled
Size perforation 3/32
From feet to feet
From 123 feet to 143 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 143 feet

9. WATER LEVEL
Static water level 110 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Clean

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Enloe Drilling (Contractor)
Address P.O. Box 1345 (Contractor) Payton, Nev. 89403
Nevada contractor's license number issued by the State Contractor's Board 4739A
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1480
Signed Lee A. Enloe (By driller performing actual drilling on site or contractor)
Date Oct 9, 1993

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627