WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42988
Permit No.
Basin

NOTICE OF INTENT NO. 12240

1. OWNER JOHN AUSTIN
MAILING ADDRESS
ADDRESS AT WELL LOCATION LOT 8 MONEY ST
PAHRUMP NV

2. LOCATION NE ¼ SW ¼ Sec. 2 T. 21S N/S R. 53 E. NYE County
PERMIT NO. (Issued by Water Resources) 44-211-01 (Parcel No.) RANCHO VIEW ESTATES (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	3	3
CALICHIE		3	5	2
CLAY		5	14	9
CALICHIE		14	19	5
CLAY		19	27	8
CALICHIE	WB	27	32	5
CLAY		32	48	16
CALICHIE	WB	48	53	5
CLAY		53	60	7
CALICHIE	WB	60	62	2
CLAY		62	74	12
CALICHIE	WB	74	77	3
CLAY		77	91	14
CALICHIE	WB	91	93	2
CLAY		93	99	6
CALICHIE	WB	99	101	2
CLAY		101	108	7
CALICHIE	WB	108	112	4
CLAY		112	117	5
CALICHIE	WB	117	121	4
CLAY		121	132	11
CALICHIE	WB	132	134	2
CLAY		134	140	6
		140		140

Date started 9-7-93, 19
Date completed 9-8-93, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
OCT 13 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
12.25	0	140

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.9	.188	0	140

Perforations:
Type perforation FACTORY SAW CUT
Size perforation 1/8 X 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 52 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING CO. INC. (Contractor)
Address HCR 78 BOX 80358 PAHRUMP NV 89060 (Contractor)
Nevada contractor's license number 30880 issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan (By driller performing actual drilling on site or contractor)
Date 10-1-93

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 3-91) (O)-627