WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 42991
Permit No.
Basin 162

NOTICE OF INTENT NO.

1. OWNER JACK TOOLY
MAILING ADDRESS
ADDRESS AT WELL LOCATION LOT 14 IRENE ST PAHRUMP NV

2. LOCATION NW ¼ NE ¼ Sec. 8 T. 21S N/S R. 53 E. NYE County
PERMIT NO. (Issued by Water Resources) 34-151-12 (Parcel No.) CAL VEGAS (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	7	7
CALICHIE		7	9	2
CLAY		9	16	7
CALICHIE		16	18	2
CLAY		18	22	4
CALICHIE		22	24	2
CLAY		24	35	11
CALICHIE		35	38	3
CLAY		38	46	8
CALICHIE	WB	46	49	3
CLAY		49	55	6
CALICHIE	WB	55	57	2
CLAY		57	68	11
CALICHIE	WB	68	71	3
CLAY		71	79	8
CALICHIE	WB	79	81	2
CLAY		81	92	11
CALICHIE	WB	92	94	2
CLAY		94	107	13
CALICHIE	WB	107	109	2
CLAY		109	118	9
CALICHIE	WB	118	124	6
CLAY		124	131	7
CALICHIE	WB	131	133	2
CLAY		133	136	3
CALICHIE	WB	136	139	3
CLAY		139	140	1
		140		140

Date started 9-22-93, 19
Date completed 9-25-93, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
NOV 12 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12.25 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
85\8	16.9	.188	0	140

Perforations:
Type perforation FACTORY SAW CUT
Size perforation 1\8 X 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout
Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 46 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING CO. INC. (Contractor)
Address HCR 78 BOX 80358 PAHRUMP NV 89041 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dun (By driller performing actual drilling on site or contractor)
Date 10-23-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627