

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 12249

1. OWNER DAKS ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_ LOT 538 TURNER  
 \_\_\_\_\_ PAHRUMP NV  
 2. LOCATION SW  $\frac{1}{4}$  SW  $\frac{1}{4}$  Sec 20 T 21S N/S R. 54 E NYE County \_\_\_\_\_  
 PERMIT NO. \_\_\_\_\_ 45-303-31 GREEN SADDLE RANCH  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY DIRT		0	4	4
COBBLES CLAY		4	11	7
CALICHIE		11	21	10
CEMENTED GRAVEL		21	32	11
CLAY		32	35	3
CALICHIE		35	38	3
CLAY		38	61	23
CALICHIE J		61	63	2
CLAY		63	86	23
CALICHIE		86	91	5
CLAY		91	127	36
CALICHIE		127	131	4
CLAY		131	156	25
CALICHIE		156	159	3
CLAY		159	178	19
CALICHIE	WB	178	180	2
CLAY		180	191	11
CALICHIE	WB	191	194	3
CLAY		194	205	11
CALICHIE	WB	205	208	3
CLAY		208	223	15
CALICHIE	WB	223	229	6
CLAY		229	236	7
CALICHIE	WB	236	238	2
CLAY		238	240	2
CALICHIE	WB	240		240

8. WELL CONSTRUCTION  
 Depth Drilled 240 Feet Depth Cased 240 Feet  
 HOLE DIAMETER (BIT SIZE)  
 12.25 Inches From 0 Feet To 240 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
85 \ 8	16.9	.188	0	240

Perforations:  
 Type perforation FACTORY SAW CUT  
 Size perforation 1 \ 8 X 3"  
 From 200 feet to 220 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
50 Depth of Seal \_\_\_\_\_  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 240 feet

9. WATER LEVEL  
 Static water level 42 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name GREAT BASIN DRILLING CO. INC.  
 Contractor  
 Address HCR 78 BOX 80358  
PAHRUMP NV 89041  
 Contractor  
 Nevada contractor's license number 30880  
 issued by the State Contractor's Board  
 Nevada driller's license number issued by the 1642  
 Division of Water Resources, the on-site driller  
 Signed Thomas D...  
 By driller performing actual drilling on site or contractor  
 Date 10-27-93

Date started 9-22-93 19\_\_\_\_\_  
 Date completed 9-25-93 19\_\_\_\_\_

7. WELL TEST DATA  
 TEST METHOD:  Bailer  Pump  Air Lift  

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

 Div. of Water Resources  
 Branch Office - Las Vegas, NV

RECEIVED  
 NOV 12 1993  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV