WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43061
Permit No.
Basin 6-87

NOTICE OF INTENT NO. 23914

1. OWNER Hilton Pollock 6949
MAILING ADDRESS Windy Hill Way
ADDRESS AT WELL LOCATION 6949 Windy-Hill Way Reno

2. LOCATION SW ¼ SW ¼ Sec. 36 T. 19 N/S R. 19 E. Washoe County
PERMIT NO. Issued by Water Resources | Parcel No. 41-100-39 | Subdivision Name

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
190' was found to be the bottom				
when pumping cement we did not have any water return				
when perforating at 50' we found cement				

'93 OCT 11 P2:01
STATE ENGINEERS OFFICE

Date started 9/22/ 1993
Date completed 9/23/ 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

'93 DEC -7 AM 10:01
STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
Depth Drilled ..... Feet Depth Cased ..... Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0 Feet	190 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)

Perforations:
Type perforation Mills Knife 4 slots per
Size perforation Foot
From ..... feet to ..... feet
From 190 feet to 50 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 27 sack
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☒ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From ..... feet to ..... feet
4 yards of cement were used

9. WATER LEVEL
Static water level ..... feet below land surface
Artesian flow ..... G.P.M. ..... P.S.I.
Water temperature ..... °F Quality .....

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name McKay Drilling
Contractor
Address 2290 Pioneer Drive
Contractor
Reno, Nevada 89507
Nevada contractor's license number issued by the State Contractor's Board 14170
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1476
Signed Steve McKay
By driller performing actual drilling on site or contractor
Date 10/6/93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627