

OFFICE USE ONLY
 Log No. 43066
 Permit No. 1
 Basin 30A

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 47021

1. OWNER RIO KING RANCH ADDRESS AT WELL LOCATION KINGS RIVER, NV.
 MAILING ADDRESS KINGS RIVER VALLEY N41.916803
P.O. BOX 122 OROVADA, NV. 89425 W 118.219573 NAD27

2. LOCATION N.W. 1/4 N.W. 1/4 Sec. 1 T. 45 N N/S R. 33 E. HUMBOLDT County
 PERMIT NO. 19522 NONE NONE
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	10	10
CRSE SAND WITH SMALL GRAVEL		10	20	10
clay STRKS COURSE SAND		20	40	20
MED TO CRSE SAND SMALL GRAVEL		40	65	25
BRN CLAY CRSE SAND		65	75	10
SAND GRAVEL STRKS CLAY		75	133	58
CRSE SAND		133	135	2
CRSE SAND CLAY STRK		135	170	35
CRSE SAND GRAVEL ROCK STRK		170	205	35
CLAY		170	205	35
BRN CLAY SAND STRKS		205	255	50
SAND GRAVEL CLAY STRK.		255	295	40
BRN SANDY CLAY		295	305	10
CRSE SAND GRAVEL STRK		305	355	50
CLAY		305	355	50
CRSE SAND GRAVEL CHNK CLAY		355	375	30
BRN CLAY STRK SAND		375	377	2
CRSE SAND GRAVEL		377	383	6
BRN CLAY STRK SAND		383	395	12
SAND STRK CLAY		395	405	10
STRK CLAY CRSE SAND GRAVEL		405	495	90
ROCK		405	495	90
BRN CLAY CRSE SAND MIX		495	505	10
CRSE SAND GRAVEL		505	515	10
BRN CLAY STRKCRSE SAND		515	530	15
STRK CLAY SAND GRAVEL MIX		530	552	22
CRSE SAND GRAVEL		552	565	13
CRSE SAND GRAVEL STRKS CLAY		565	602	37
BRN CLAY		602	605	3

8. WELL CONSTRUCTION
 Depth Drilled 605 Feet Depth Cased 600 Feet

HOLE DIAMETER (BIT SIZE)
 From To
26" Inches 0 Feet 605 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
18"	59.03	.312	+ 1	190
18"	59.03	.312	590	600

Perforations: SCREENS
 Type perforation JOHNSONS SAND SCREEN
 Size perforation 80 slot
 From 190' feet to 590' feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50' feet to 605 feet

9. WATER LEVEL
 Static water level 92' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name PETE COPE DRILLING CO. INC. Contractor
 Address 6505 W. CHINDEN BLVD. Contractor
MERIDIAN, ID. 83642
 Nevada contractor's license number issued by the State Contractor's Board 13443
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1484
 Signed Joseph by driller performing actual drilling on site or contractor
 Date 12/6/93

Date started NOV. 17 1993
 Date completed NOV. 21 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)