WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43117
Permit No.
Basin 7-~~0008~~

NOTICE OF INTENT NO. 23421

1. OWNER Willard Noble
MAILING ADDRESS 19555 Broadhurst Road
Cottonwood, CALIFORNIA 96022
ADDRESS AT WELL LOCATION 2231 Empire
Virginia City, NV. 89440

2. LOCATION NE ¼ SE ¼ Sec. 32 T. 18 N/S R 21 E. Storey County
PERMIT NO. N/A (Issued by Water Resources) 03-072-21 (Parcel No.) Lot #132 N. Virginia Highlands (Subdivision Name)

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☑ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Orange Clay		0	35	35
Light Brown Clay		35	40	5
Gray Clay		40	65	25
Light Gray Andesite		65	105	40
Dark Gray Andesite	✓	105	200	95

Date started 11-12, 19 93
Date completed 11-13, 19 93

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Developed for 2 Hours and produced about 25 Gallons A-min		

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 5/8 Inches	0 Feet	60 Feet
8 3/4 Inches	60 Feet	200 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13.00	3/16	+1	200

Perforations:
Type perforation Torch Cut
Size perforation 8 x 5 x 6 Rowes
From 160 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 0-50
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☑ No
From feet to feet

9. WATER LEVEL
Static water level 70 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Leach Drilling Inc (Contractor)
Address Po Box 599 Silver Springs NV 89429 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board #0031841
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1877
Signed [signature] (By driller performing actual drilling on site or contractor)
Date

NOV 29 '93 P1:52 STATE ENGINEER'S OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627