WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43138
Permit No.
Basin 6-87

NOTICE OF INTENT NO. 18106

1. OWNER Municipal Court Building
MAILING ADDRESS Sparks, Nv.
ADDRESS AT WELL LOCATION N.W. Corner of B St. + Pyramid Way

2. LOCATION SE ¼ SE ¼ Sec. 5 T. 19 N/S R. 20 E. Washoe County
PERMIT NO. M10 721 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☑ Air ☑ Other ~~Geiger~~ Tube

6. LITHOLOGIC LOG MW-1

Material	Water Strata	From	To	Thickness
Paving stones + sand		0	.5'	.5'
silty clay		.5'	7'	6.5'
gravel-sand-clay mixture		7'	20'	13'
gravel-sand-silt mixture	Yes	20'	21.5'	1.5'
silty sand		21.5'	22'	.5'
gravel-sand-silt mixture		22'	30'	8'

Date started 10/25, 1993
Date completed 10/25, 1993

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
N/A		

8. WELL CONSTRUCTION
Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
5⅝ Inches	0 Feet	30 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2		PVC Sch 40	0	15

Perforations:
Type perforation factory slot
Size perforation .020
From 15 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 5'
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 5' feet to 30 feet

9. WATER LEVEL
Static water level 20 feet below land surface
Artesian flow N/A G.P.M. N/A P.S.I.
Water temperature cold °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Andresen Drilling (Contractor)
Address 1635 Belford Road (Contractor)
Reno, NV.
Nevada contractor's license number issued by the State Contractor's Board 34525
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 11/26/93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627