



PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23387

1. OWNER RICHARD ROSE ADDRESS AT WELL LOCATION Same
 MAILING ADDRESS 2035 East Lake Blvd.
Carson City, NV 89704

2. LOCATION SW 1/4 NE 1/4 Sec 30 T. 17N N/S R. 20 E Washoe County
 PERMIT NO. 050-385-01 Washoe Valley Subdivision Name
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
WELL ABANDONMENT:				
STATIC WATER LEVEL AT 48 FEET.				
TOTAL DEPTH OF WELL AT 57 FEET.				
Attempt to pull casing. No go.				
Perforate with down hole air perforator.				
Perforate 4 rows around/est 1000 perforations				
Set tremie line to 57 feet.				
Pump 18 sacks of Cement type II, fill hole to surface. Pull tremie pipe.				
12-8-93				
Cut casing below grade.				
Finish with 11 sacks of Cement type II.				
Location:				
SE corner of property				
15 feet off S fence				
33 feet off E fence				

8. WELL CONSTRUCTION
 Depth Drilled 57 Feet Depth Cased 57 Feet

HOLE DIAMETER (BIT SIZE)
 From To
 Inches Feet Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<i>ABANDON</i>				

Perforations:
 Type perforation _____
 Size perforation _____
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From _____ feet to _____ feet

Date started 12-6-93, 19____
 Date completed 12-8-93, 19____

7. WELL TEST DATA

TEST METHOD: Bailor Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL
 Static water level 48 feet below land surface
 Artesian flow not known G.P.M. _____ P.S.I. _____
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Wayne Drilling, Inc.
 Address P.O. Box 12370
Reno, NV 89510
 Nevada contractor's license number 22549
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 908
 Division of Water Resources, the on-site driller
 Signed Wayne C. Helman
 By driller performing actual drilling on site or contractor
 Date December 26, 1993