

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 23791

1. OWNER Carl Eakin ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS P. O. Box 365 11085 Wagon Ho
Lincoln, CA 95648 Parcel 1 of Map 76
 2. LOCATION NE 1/4 SW 1/4 Sec. 25 T. 21 ONS R. 1817 E Washoe County
 PERMIT NO. 86-340-23 Silver Knolls
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE Cable Rotary RVC
 Air Other Mud

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Fine silty clay & sands		0	18	18
Coarse sands & gravels		18	27	9
Sticky tan clay with small layers of sands tan yellow green red in color		27	65	38
Sticky green clay		65	117	52
Green sticky clay with small sand layers		117	124	7
Coarse sands & gravels green tan white red		124	138	14
Sticky dark green clay		138	141	3
T.D. 141 ft				

8. WELL CONSTRUCTION
 Depth Drilled 141 Feet Depth Cased 141 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 141 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12.92</u>	<u>.188</u>	<u>+ 2</u>	<u>141</u>

Perforations:
 Type perforation factory
 Size perforation 3/32 X 3
 From 121 feet to 141 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 54 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 54 feet to 141 feet

9. WATER LEVEL
 Static water level 40 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started 10/13/93, 19_____
 Date completed 10/14/93, 19_____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20+</u>		<u>1 1/2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Aqua Drilling & Well Service, Inc Contractor
 Address 625 Spice Islands Dr Suite L
Sparks, Nv 89431 Contractor
 Nevada contractor's license number 15291
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1132
 Division of Water Resources, the on-site driller
 Signed Roger M Thrall
 By driller performing actual drilling on site or contractor
 Date Roger M. Thrall 10/15/93