

OFFICE USE ONLY  
 Log No. 43213  
 Permit No. \_\_\_\_\_  
 Basin 8-104 103

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24467

1. OWNER Slav / Jennie Kolupeav ADDRESS AT WELL LOCATION 1677 Quail Ln Carson City NV 89702  
 MAILING ADDRESS 1677 Quail Ln Carson City NV 89702  
 2. LOCATION N10 1/4 NW 1/4 Sec 23 T 15 S R 20 E Carson County  
 PERMIT NO. 16-094-06 Parcel No. \_\_\_\_\_ Subdivision Name Deer Run Sub.  
 Issued by Water Resources \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Overburden		0	6	6
Cemented Gravels		6	53	47
Rusty Clay		53	75	22
DC Sands		75	135	60
Course DC Sands		135	178	43
Black Shale		178	260	82
Shale with Rusty Stained Rock		260	290	30
Course Volcanic Gravels		290	320	30

93 DEC -6 P 116  
 STATE ENGINEERS

8. WELL CONSTRUCTION  
 Depth Drilled 320 Feet Depth Cased 320 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 1 1/4 Inches To 0 Feet 320 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>320</u>

 Perforations:  
 Type perforation Mill Slot  
 Size perforation 3/32 X 3  
 From 280 feet to 320 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 50  Cement Grout  
 Placement Method:  Pumped  Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 320 feet

9. WATER LEVEL  
 Static water level 275 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 15 P.S.I.  
 Water temperature cold °F Quality Good

Date started 12-1, 1993  
 Date completed 12-6, 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>15</u>	<u>25</u>	<u>3 Hrs</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name \_\_\_\_\_  
 Contractor A & W PUMP CO.  
 Address 3551 Hwy 50 East Carson City Nevada 89702  
 Nevada contractor's license number issued by the State Contractor's Board 31839  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905  
 Signed Michael Z Hock  
 By driller performing actual drilling on site or contractor  
 Date 12-6-93