

OFFICE USE ONLY
 Log No. 413270
 Permit No. 1
 Basin B+104

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21152

1. OWNER Carsonite International Fac. ADDRESS AT WELL LOCATION same
 MAILING ADDRESS Carson City, NV
1301 Hot Springs Rd. west side
 2. LOCATION NE 1/4 SE 1/4 Sec. 5 T. 15 N. S. R. 20 E. County
 PERMIT NO. M/0 687A Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other auger

6. C-1-3 LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
concrete slab		0	1'	1'
silty sand		1'	2'	1'
sand w/ silt		2'	5'	3'
sand w/ silt		5'	7.5'	2.5'
silty sand w/ clay	yes	7.5'	9'	1.5'
silty sand w/ gravel		9'	15'	6'
silty sand w/ clay		15'	20'	5'

93 DEC 29 AM 1:46
 STATE ENGINEER

8. WELL CONSTRUCTION
 Depth Drilled 20 Feet Depth Cased 20 Feet
 HOLE DIAMETER (BIT SIZE)
 From 8 Inches To 20 Feet
 Inches Feet Feet
 Inches Feet Feet
 Inches Feet Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>		<u>DYCSch 40</u>	<u>0</u>	<u>25</u>

 Perforations:
 Type perforation factory slot
 Size perforation .020
 From 5 feet to 20 feet
 From feet to feet
 From feet to feet
 From feet to feet
 From feet to feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 4' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 4' feet to 20 feet

Date started 8/13 19 93
 Date completed 8/13 19 93

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

N/A

9. WATER LEVEL
 Static water level 7.5 feet below land surface
 Artesian flow N/A G.P.M. N/A P.S.I.
 Water temperature COLD °F Quality N/A

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Andresen Drilling Contractor
 Address 1635 Belford Road Contractor
RENO, NV
 Nevada contractor's license number issued by the State Contractor's Board 34525
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028
 Signed Frank Andresen
 By driller performing actual drilling on site or contractor
 Date 11/26/93