

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 43230  
 Permit No. \_\_\_\_\_  
 Basin 8-104

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 12268

1. OWNER Old Supreme Court Building ADDRESS AT WELL LOCATION Same  
 MAILING ADDRESS Carson City, NV

2. LOCATION NE 1/4 SE 1/4 Sec. 17 T. 15 N. R. 20 E. CARSON County  
 PERMIT NO. M/O 659 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Alger

6. LITHOLOGIC LOG MU-3

Material	Water Strata	From	To	Thick-ness
<u>Silty Sand dk brn</u>		<u>0</u>	<u>3'</u>	<u>3'</u>
<u>SAND brn</u>		<u>3'</u>	<u>11'</u>	<u>8'</u>
<u>Silty sand brn</u>		<u>11'</u>	<u>16'</u>	<u>5'</u>
<u>gravelly sand lt brn</u>	<u>yes</u>	<u>16'</u>	<u>22'</u>	<u>6'</u>
<u>SAND - olive brn</u>		<u>22'</u>	<u>25'</u>	<u>3'</u>

8. WELL CONSTRUCTION  
 Depth Drilled 25 Feet Depth Cased 25 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 25 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4</u>		<u>sch. 40</u>	<u>0</u>	<u>25</u>

Perforations:  
 Type perforation factory 5/121  
 Size perforation 0.20  
 From 10 feet to 25 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 3'  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 3 feet to 25 feet

9. WATER LEVEL  
 Static water level 16 feet below land surface  
 Artesian flow no G.P.M. n/a P.S.I.  
 Water temperature 60.0 °F Quality 10/10

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Anderson Drilling Contractor  
 Address 1635 Bedford Rd, Reno NV Contractor  
 Nevada contractor's license number 34525 issued by the State Contractor's Board.  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1028  
 Signed [Signature]  
 Date 6-30-93  
 By driller performing actual drilling on site or contractor

Date started 4/23 1993  
 Date completed 4/23 1993

7. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>NA</u>	<u>NA</u>	