



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24275

1. OWNER DENNIS CLARK CONSTRUCTION ADDRESS AT WELL LOCATION 1781 FISH SPRINGS RD. GARDNERVILLE
 MAILING ADDRESS GARDNERVILLE, NV

2. LOCATION NE 1/4 NE 1/4 Sec. 2 T. 12 N. R. 20 E. DOUGLAS County EAST VALLEY
 PERMIT NO. 23-480-41 Parcel No. _____ Subdivision Name _____
 Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MWD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY CLAY		0	4	4
SANDY CLAY W/GRAVEL		4	9	5
CEMENTED GRAVEL		9	31	22
SANDY CLAY		31	58	27
SANDY CLAY W/GRAVEL		58	96	38
CLAY		96	99	3
SANDY CLAY		99	148	49
CLAY		148	206	58
SANDY CLAY W/GRAVEL		206	211	5
CLAY		211	216	5
SANDY CLAY W/GRAVEL		216	228	12
SAND + GRAVEL	✓	228	256	28
CLAY		256	258	2
SAND + GRAVEL	✓	258	274	16
CLAY		274	275	1

8. WELL CONSTRUCTION
 Depth Drilled 275 Feet Depth Cased 275 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 To 275
105/8 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>65/8</u>	<u>12</u>	<u>.188</u>	<u>0</u>	<u>275</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 X 3/32
 From 255 feet to 275 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 50

Placement Method: Pumped
 Poured

Gravel Packed: Yes No
 From 50 feet to 275 feet

9. WATER LEVEL
 Static water level 90 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

Date started 11-10, 1993
 Date completed 11-18, 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>25+</u>	<u>-</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name EDDCO EXPLORATION, INC. Contractor
 Address 7780 CURRY RD. FALLON, NV 89406 Contractor

Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726

Signed Pat J. Mow
 By driller performing actual drilling on site or contractor
 Date 11-18-93

93 NOV 30 AM 10:05
 RECEIVED
 STATE ENGINEERS OFFICE