WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43242
Permit No.
Basin 8-105

NOTICE OF INTENT NO. 24329

1. OWNER MR. POTTER
MAILING ADDRESS MINDEN, NV
ADDRESS AT WELL LOCATION 2543 FREMONT MINDEN, NV

2. LOCATION SE ¼ NW ¼ Sec. 2 T. 13 (N) S R. 20 E. DOUGLAS County
PERMIT NO. — (Issued by Water Resources) | Parcel No. 23-510-04 | Subdivision Name JOHNSON LANE

3. WORK PERFORMED: [X] New Well [X] Replace [ ] Recondition [ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE: [X] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE: [ ] Cable [X] Rotary [ ] RVC [ ] Air [X] Other M.V.D.

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
fine sand		0	15	15
Sandy clay		15	55	
small gravel w/ sandy clay		55	67	
Sandy clay some gravel		67	85	
Sandy clay w gravel		85	160	
gravel w sand		160	164	
Small gravel w sandy clay		164	210	
Sandy clay w some gravel		210	227	
Small gravel w Sandy clay	X	227	250	
Sandy clay some gravel		250	273	
Small gravel w sandy clay	X	273	280	
Sandy clay w course sand		280	325	
gravel w Sandy clay	X	325	334	
Sandy clay some gravel		334	341	
gravel w Sandy clay	X	341	344	
Sandy clay w course sand	X	344	360	
Sandy clay w some gravel		360	362	

Date started 10-13, 1993
Date completed 10-29, 1993

7. WELL TEST DATA

TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
Air	25+		5

8. WELL CONSTRUCTION
Depth Drilled 362 Feet Depth Cased 362 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	362 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12	.188	0	362

Perforations:
Type perforation Factory Slotted / Torch cut
Size perforation 3 x 3/32
From T.C. 230 feet to 240 feet
From T.C. 280 feet to 300 feet
From T.C. 320 feet to 340 feet
From Factory 340 feet to 362 feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50'
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 362 feet

9. WATER LEVEL
Static water level 129' feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDDCO EXPLORATION, INC (Contractor)
Address 7780 CURRY RD. (Contractor)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 27673
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
Signed Gerald W. Kimmell (By driller performing actual drilling on site or contractor)
Date 10-30-93

NOV 30 '93 A11:04 STATE ENGINEER

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627