WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43345
Permit No.
Basin 8-105

NOTICE OF INTENT NO. 24272

1. OWNER BILLY FRANK BOLT
MAILING ADDRESS GARDNERVILLE
ADDRESS AT WELL LOCATION 1571 SCOTT GARDNERVILLE, NV

2. LOCATION NE ¼ SE ¼ Sec. 34 T 13 (N)S R 20 E DOUGLAS County
PERMIT NO. — (Issued by Water Resources) 23-260-58 (Parcel No.) SIERRA SUNSET HEIGHTS (Subdivision Name)

3. WORK PERFORMED: [X] New Well [ ] Replace [ ] Recondition [ ] Deepen [ ] Abandon [ ] Other
4. PROPOSED USE: [X] Domestic [ ] Irrigation [ ] Test [ ] Municipal/Industrial [ ] Monitor [ ] Stock
5. WELL TYPE: [ ] Cable [X] Rotary [ ] RVC [ ] Air [X] Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY LOAM		0	3	3
CLAY		3	7	4
SANDY CLAY		7	12	5
SAND		12	17	5
SAND + GRAVEL		17	24	7
SANDY CLAY w/GRAVEL		24	40	16
CEMENTED GRAVEL		40	76	36
SANDY CLAY w/GRAVEL		76	82	6
CLAY		82	95	13
SAND + GRAVEL	✓	95	119	24
SANDY CLAY		119	134	15
COARSE SAND + GRAVEL	✓	134	143	9
CLAY		143	150	7

Date started 11-19, 1993
Date completed 11-23, 1993

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
AIR	25+	—	1

8. WELL CONSTRUCTION
Depth Drilled 150 Feet Depth Cased 150 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 5/8 Inches		0 Feet	150 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12	.188	0	150

Perforations:
Type perforation FACTORY SLOTTED
Size perforation 3 x 3/32
From 125 feet to 145 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 150 feet

9. WATER LEVEL
Static water level 20 feet below land surface
Artesian flow — G.P.M. — P.S.I.
Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EDDCO EXPLORATION, INC (Contractor)
Address 7780 CURRY RD. (Contractor)
FALLON, NV 89406
Nevada contractor's license number issued by the State Contractor's Board 27673
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 11-23-93

STATE ENGINEER'S OFFICE
'93 NOV 30 A11:05

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627