

OFFICE USE ONLY
 Log No. 43254
 Permit No. 8-105
 Basin

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24327

1. OWNER JOHN DECARLO CONST. ADDRESS AT WELL LOCATION 2644 KAYNE MINDEN, NV
 MAILING ADDRESS GARDNERVILLE, NV

2. LOCATION SW 1/4 SW 1/4 Sec 34 T. 14 N. R. 20 E. DOUGLAS County
 PERMIT NO. 21-201-15 JOHNSON LANE Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MVD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
fine sand		0	13	13
sandy clay some gravel		13	48	36
gravel w sandy clay		48	58	20
sandy clay		58	73	5
gravel w sandy clay		73	81	8
sandy clay		81	88	7
Sandy clay w gravel ^{small}	X	88	113	25
Sandy clay		113	123	10
Sandy clay w gravel ^{small}	X	123	131	8
Sandy clay some gravel	X	131	142	11
course sand w gravel ^{small}	XX	142	160	18

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)
 From To
10 7/8 Inches 0 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>12</u>	<u>.188</u>	<u>0</u>	<u>160</u>

Perforations:
 Type perforation Full length slot
 Size perforation 3.1 3/2
 From 140 feet to 160 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 160 feet

9. WATER LEVEL
 Static water level 19 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD. FALLON, NV 89406 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
 Signed Sherald Williams By driller performing actual drilling on site or contractor
 Date 11-1-93

Date started 10-29, 1993
 Date completed 11-1, 1993

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>Air</u>	<u>25+</u>		<u>1</u>

'93 NOV 30 AM 10:04
 STATE ENGINEERS OFFICE