

OFFICE USE ONLY
Log No. 43270
Permit No. 53031
Basin. 142

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 16207

1. OWNER American Res ADDRESS AT WELL LOCATION _____
MAILING ADDRESS Box 110 #16 _____
Coldfield NV 89013 _____
2. LOCATION NE 1/4 SW 1/4 Sec 26 T. 2 R. 42 E. ESMEALDA County _____
PERMIT NO. 53031-53036 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP Soil		0	3	3
Granite		3	324	
Fractured	X	324	375	
Granite		375	387	
Fractured	X	387	418	
Granite		418	481	
Fractured	X	481	535	
Granite		535	550	

93 NOV 29 P1 50
STATE ENGINEERS OFFICE

8. WELL CONSTRUCTION
Depth Drilled: 550 Feet Depth Cased: 550 Feet
HOLE DIAMETER (BIT SIZE)
From 10 Inches To 550 Feet
Inches _____ Feet _____
Inches _____ Feet _____
CASING SCHEDULE
Size O.D. (Inches) Weight/Ft. (Pounds) Wall Thickness (Inches) From (Feet) To (Feet)
6 ~~188~~ 188 0 550
Perforations:
Type perforation: Factory
Size perforation:
From 366 feet to 340 feet
From 380 feet to 430 feet
From 450 feet to 540 feet
From _____ feet to _____ feet
Surface Seal: Yes No Seal Type: Neat Cement
Depth of Seal: 50 Cement Grout
Placement Method: Pumped Concrete Grout
 Poured
Gravel Packed: Yes No
From 50 feet to 550 feet
9. WATER LEVEL
Static water level: 36 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature _____ °F Quality _____

Date started 10-10- 1993
Date completed 11-12- 1993

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input checked="" type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>112</u>		<u>12</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name AAA Drilling Contractor
Address 181-14 W. Bullion Contractor
ELKO, NV
Nevada contractor's license number issued by the State Contractor's Board DD20684
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1435
Signed Shaw Bennett
By driller performing actual drilling on site or contractor
Date 11-12-93