

OFFICE USE ONLY  
 Log No. 43299  
 Permit No. 162  
 Basin. 162



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 12255

1. OWNER RICHARD LITTLE ADDRESS AT WELL LOCATION LOT 2 TECOPA ST PAHRUMP NV  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION SW 1/4 NE 1/4 Sec. 16 T. 19S N/S R. 53 E NYE County Country Place 11  
 PERMIT NO. 29-211-03 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	8	8
CALICHIE		8	12	4
CLAY		12	21	9
CALICHIE		21	24	3
CLAY		24	33	9
CALICHIE		33	38	5
CLAY		38	56	18
CALICHIE		56	58	2
CLAY		58	77	19
GRAVEL	WB	77	82	5
CLAY		82	95	13
CALICHIE	WB	95	104	9
CLAY		104	109	5
GRAVEL	WB	109	112	3
CLAY		112	127	15
CALICHIE	WB	127	142	15
SAND		142	160	18
CALICHIE	WB	160	163	3
CLAY		163	175	12
CALICHIE	WB	175	178	3
CLAY		178	180	2
		180		180

8. WELL CONSTRUCTION  
 Depth Drilled 180 Feet Depth Cased 180 Feet

HOLE DIAMETER (BIT SIZE)  
 From 0 To 180 Feet  
12.25 Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
85 \ 8	16.9	.188	0	180

Perforations:  
 Type perforation FACTORY SAW CUT  
 Size perforation 1 \ 8 x 3"  
 From 160 feet to 180 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 180 feet

9. WATER LEVEL  
 Static water level 90 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name GREAT BASIN DRILLING CO. INC. Contractor  
 Address HCR 78 BOX 80358 PAHRUMP NV 89041 Contractor

Nevada contractor's license number 30880 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642  
 Signed Thomas Durr By driller performing actual drilling on site or contractor  
 Date 10-23-93

Date started 10-4-93, 19\_\_\_\_  
 Date completed 10-8-93, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<b>RECEIVED</b>			
<b>NOV 12 1993</b>			
Div. of Water Resources Branch Office - Las Vegas, NV			