WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43340
Permit No.
Basin 162

NOTICE OF INTENT NO. 12072

1. OWNER DON ROOT
MAILING ADDRESS
ADDRESS AT WELL LOCATION JARVIS ST
PAHRUMP NV

2. LOCATION SE ¼ SW ¼ Sec 28 T 19S N/S R 53 E NYE County
PERMIT NO. (Issued by Water Resources) 29-901-13 (Parcel No.) BELLVISTA 3 (Subdivision Name)

3. WORK PERFORMED
X ☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
X ☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
CLAY		0	8	8
CALICHIE		8	10	2
CLAY		10	20	10
CALICHIE		20	22	2
CLAY		22	29	7
CALICHIE		29	32	3
CLAY		32	40	8
CALICHIE		40	42	2
CLAY		42	49	7
CALICHIE		49	53	4
CLAY		53	66	13
CALICHIE	WB	66	70	4
CLAY		70	87	17
CALICHIE	WB	87	89	2
CLAY		89	95	6
CALICHIE	WB	95	97	2
CLAY		97	104	7
CALICHIE	WB	104	108	4
CLAY		108	117	9
CALICHIE	WB	117	119	2
CLAY		119	129	10
CALICHIE	WB	129	131	2
CLAY		131	135	4
CALICHIE	WB	135	138	3
CLAY		138	140	2
		140		140

Date started 11-23-93, 19
Date completed 11-26-93, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
DEC 28 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12.25 Inches		0 Feet	140 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
85\8	16.9	.188	0	140

Perforations:
Type perforation FACTORY SAW CUT
Size perforation 1\8 X 3"
From 100 feet to 120 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: X ☐ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped X ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout X ☐ Concrete Grout
Gravel Packed: X ☐ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 62 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name GREAT BASIN DRILLING CO. INC. (Contractor)
Address HCR 78 BOX 80550 (Contractor)
PAHRUMP NV 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 642
Signed (By driller performing actual drilling on site or contractor)
Date 12-11-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627