


Log No. 43391

Permit No. \_\_\_\_\_

Basin. 162



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 12 469

1. OWNER Gorden McGrew ADDRESS AT WELL LOCATION Lot 20 Verbena St  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION SW 1/4 S1E 1/4 Sec 20 T. 20S N/S R. S3 E Nye County \_\_\_\_\_  
 PERMIT NO. \_\_\_\_\_ CALVADA VALLEY Subdivision Name \_\_\_\_\_  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	8	8
caliche		8	32	24
Clay		32	41	9
caliche		41	44	3
Clay		44	49	5
caliche		49	51	2
Clay		51	58	7
caliche	wb	58	61	3
Clay		61	81	20
caliche	wb	81	92	11
Clay		92	107	17
caliche	wb	107	111	4
Clay		111	119	8
caliche	wb	119	123	4
Clay		123	134	11
caliche	wb	134	137	3
Clay		137	140	3

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)  
 From 12 1/4 Inches To 140 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet

8. CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.44</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:  
 Type perforation Factory Sme-cut  
 Size perforation 1/4 x 3  
 From 100 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

9. WATER LEVEL  
 Static water level 55 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 11-23, 1993  
 Date completed 11-26, 1993

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<b>RECEIVED</b>		
JAN 11 1994		
Div. of Water Resources Branch Office - Las Vegas, NV		

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Great Basin Drilling Contractor  
 Address HCR 78 Box 80358 Contractor  
Pahrump NV 89041  
 Nevada contractor's license number issued by the State Contractor's Board 30886  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642  
 Signed Thomas Dun  
 By driller performing actual drilling on site or contractor  
 Date 12/21/93