WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 43393
Permit No.
Basin

NOTICE OF INTENT NO. 12617

1. OWNER Erich Schuerger
MAILING ADDRESS
ADDRESS AT WELL LOCATION 420 W. Hickory St.

2. LOCATION SW ¼ SE ¼ Sec 28 T 20-S N/S R 53 E Nye County
PERMIT NO. (Issued by Water Resources) 40-401-18 (Parcel No.) Calvada Valley Unit 5 (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	4	4
Brown clay/caliche		4	13	9
Brown clay		13	28	15
Brown clay/caliche		28	48	20
Brown clay		48	61	13
Brown clay/caliche	X	61	117	56
Brown clay	X	117	160	43

RECEIVED
JAN 14 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started January 5, 1994
Date completed January 5, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20	4	½

8. WELL CONSTRUCTION
Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches		0 Feet	160 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.188	0	160

Perforations:
Type perforation Torch Cut
Size perforation ¼in. width 8in. long
From 120 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 160 feet

9. WATER LEVEL
Static water level 46 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name JIM PIKE WELL DRILLING (Contractor)
Address P.O. BOX 56 (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 17563
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1324
Signed Jim Pike (By driller performing actual drilling on site or contractor)
Date January 12, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627