

OFFICE USE ONLY
 Log No. 13401
 Permit No. _____
 Basin: _____

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 12386

1. OWNER WILLIAM & LAURA BURD ADDRESS AT WELL LOCATION CALVARY STREET
PAHRUMP, NEVADA 89041
LAGOONA NIGUEL, CA 92677 (371 CALVARY)
 2. LOCATION S-E 1/4 N-W 1/4 Sec 34 T. 20 S. N/S R. 53 E E. NYE County
 PERMIT NO. 40-663-09 CALVADA VALLEY UNIT 4-A
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
SANDY SOIL		0	6	6
BROWN CLAY		6	13	7
CALICHE		13	19	6
BROWN CLAY	X	19	130	111
HARD BROWN CLAY	X	130	140	10

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 Inches 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17	188	0	140

Perforations:
 Type perforation FACTORY
 Size perforation 3X16X4
 From 120 feet to 140 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 140 feet

9. WATER LEVEL
 Static water level 50' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

RECEIVED
 FEB 02 1994
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started JANUARY 24 1994, 19____
 Date completed JANUARY 28 1994, 19____

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>300</u>	<u>7</u>	<u>1/2 hour</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name LARRY'S WATER WELL SERVICE Contractor
 Address P.O. BOX 3392 PAHRUMP, NV 89041 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0035901
 Nevada driller's license number issued by the Division of Water Resources, the on site driller 1916
 Signed Larry H Jenkins
 By driller performing actual drilling on site or contractor
 Date 1-28-1994