WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

In Book 14

OFFICE USE ONLY
Log No. 43448
Permit No. 54996
Basin 212

NOTICE OF INTENT NO. 12274

1. OWNER Scott Killbrew
MAILING ADDRESS 5840 N. El Capitan
Las Vegas, Nev. 89129

ADDRESS AT WELL LOCATION N/A

2. LOCATION SW ¼ SE ¼ Sec. 29 T 19 N/S R 60 E Clark County

PERMIT NO. 54996 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [ ] Test
[X] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Gravel		0	8	
Cemented Gravel		8	10	
Bentonite Clay		10	28	
Cemented Gravel		28	35	
Clay & Gravel		35	100	
Clay		100	120	
Clay &*Gravel		120	180	
Gravel & Water	xx	180	185	
Cemented Gravel		185	205	
Clay& Gravel		205	320	
Gravel & Water	xx	320	400	

RECEIVED
DEC 2 1993
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 11-17-93, 19
Date completed 11-19-93, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 1/4 Inches	0 Feet	70 Feet
10 5/8 Inches	70 Feet	400 Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8	16.94	.185	+2	400

Perforations:
Type perforation Factory
Size perforation 3/16 x 8 row
From 360 feet to 380 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 70
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout
Gravel Packed: [ ] Yes [X] No
From feet to feet

9. WATER LEVEL
Static water level 200 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name VERNON H. DIMICK (Contractor)
Address 5360 Bonita Vista (Contractor)
Las Vegas Nev 89129
Nevada contractor's license number issued by the State Contractor's Board 10062
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552
Signed V. H. Dimick (By driller performing actual drilling on site or contractor)
Date 11-24-93

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627