

OFFICE USE ONLY  
 Log No. 43479  
 Permit No. 56636  
 Basin 13-212

I

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 1153

1. OWNER Mirage Hotel/Steve Wynn ADDRESS AT WELL LOCATION Mirage Hotel  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION SW  $\frac{1}{4}$  SW  $\frac{1}{4}$  Sec. 16 T 21 N/S R. 61 E Clark County  
 PERMIT NO. 56636 Issued by Water Resources Parcel No: \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
fill type 2		0	4	4
calichi		4	6	2
brown clay & gravel		6	14	8
white clay & gravel		14	18	4
gravel	X	18	32	14
white clay & gravel		32	36	4
brown clay & gravel		36	44	8
cemented congl.		44	46	2
gravel	X	46	50	4
brown clay & gravel		50	55	5
gravel	X	55	60	5

8. WELL CONSTRUCTION  
 Depth Drilled 60 Feet Depth Cased 60 Feet

HOLE DIAMETER (BIT SIZE)  
 From 18 Inches 0 Feet To 60 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8"		.188	+1	60

Perforations:  
 Type perforation micro screen  
 Size perforation \_\_\_\_\_  
 From 20 feet to 30 feet  
 From 45 feet to 50 feet  
 From 55 feet to 60 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 3 to 5  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout

Gravel Packed:  Yes  No  
 From 5 feet to 60 feet

9. WATER LEVEL  
 Static water level 18 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ALLEN DRILLING, INC.  
 Address 4847 So. Valley View Blvd. LAS VEGAS, NEVADA 89103

Nevada contractor's license number issued by the State Contractor's Board 0018917  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1661  
 Signed Donald L. Walk  
 By driller performing actual drilling on site or contractor  
 Date 10-26-93

Date started 7/21, 19 93  
 Date completed 7/21, 19 93

7. WELL TEST DATA

TEST METHOD	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

RECEIVED

NOV 04 1993

Div. of Water Resources  
 Branch Office - Las Vegas, NV

RECEIVED  
 FEB 15 AM 10 36  
 ENGINEERS DEPT.

