

OFFICE USE ONLY  
 Log No. 45509  
 Permit No. 9-107  
 Basin 1

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 18966

1. OWNER DEAN'S WATER ADDRESS AT WELL LOCATION 42 TIT ROAD  
 MAILING ADDRESS 42 TIT ROAD WELLINGTON NV 89444  
 2. LOCATION SE  $\frac{1}{4}$  NW  $\frac{1}{4}$  Sec. 34 T. 11 N/S R. 23 County CLATSOP  
 PERMIT NO. APN 35106 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOP SOIL		0	20	
S. GRAVEL		20	65	
DC. W. BRN SANDY CLAY		65	105	
SANDY BRN CLAY		105	205	
DC. W. SANDY BRN CLAY	LV13	205	280	

'94 FEB -9 AM 128  
 STATE ENGINEER

8. WELL CONSTRUCTION  
 Depth Drilled 280 Feet Depth Cased 280 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
9 7/8 Inches 6 Feet 280 Feet  
 Inches Feet Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6</u>		<u>188</u>	<u>0</u>	<u>280</u>

Perforations:  
 Type perforation FACTORY  
 Size perforation 3/32 x 3  
 From 250 feet to 260 feet TC  
 From 260 feet to 280 feet FACTORY  
 From feet to feet  
 From feet to feet  
 From feet to feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 280 feet

9. WATER LEVEL  
 Static water level 12.0 feet below land surface  
 Artesian flow 15 G.P.M. + P.S.I.  
 Water temperature COLD °F Quality GOOD

Date started 12-13, 1993  
 Date completed 12-22, 1993

7. WELL TEST DATA

TEST METHOD:  Bailor  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>157</u>	<u>UN.</u>	<u>6 HR</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name ED MILLER Contractor  
 Address Box 92 Contractor  
SMITH NV 89430  
 Nevada contractor's license number issued by the State Contractor's Board 32166  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 718T  
 Signed Phil Beaman  
 By driller performing actual drilling on site or contractor  
 Date 12/23/93