

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO 24474

1. OWNER Carol Bailay ADDRESS AT WELL LOCATION Le 995 Franktown Rd, Washoe Valley Carson City 89706
 MAILING ADDRESS Le 995 Franktown Rd, Washoe Valley Carson City 89706
 2. LOCATION SW 1/4 SW 1/4 Sec 22 T. 16 N S R. 19 E Washoe County
 PERMIT NO. 55-180-01 Parcel No. Subdivision Name Franktown Ranches
 Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Brown overburden		0	4	4
Rusty sands		4	18	14
Bright orange clay		18	21	3
Brown sandy clay		21	54	33
Loose dg sands		54	78	24
Rusty coarse sands		78	110	32
Broken dg gravel with water		110	145	35

8. WELL CONSTRUCTION
 Depth Drilled 145' Feet Depth Cased 145' Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 145
1 1/4 Inches 0 Feet 145 Feet
 Inches Feet Feet
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>145</u>

Perforations:
 Type perforation Mill slot
 Size perforation 3/32
 From 125 feet to 145 feet
 From feet to feet
 From feet to feet
 From feet to feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100' Neat Cement
 Cement Grout
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 100' feet to 145 feet

9. WATER LEVEL
 Static water level 35' feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

Date started 2-2 19 94
 Date completed 2-4 19 94

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30</u>	<u>65</u>	<u>3 HRS</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name A & H PUMP CO
 Address 5551 Hwy. 90 East R. Carson City, Nevada, NV 89304
93-0459 883-1
005 1000
 Nevada contractor's license number issued by the State Contractor's Board 31839
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905
 Signed Michael J Haek
 By driller performing actual drilling on site or contractor.
 Date 2-4-94