



PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24841

1. OWNER Dwayne Hiemy ADDRESS AT WELL LOCATION 225 Mark Twain Ave  
 MAILING ADDRESS 225 Mark Twain Ave Dayton, Nev  
Dayton Nu 89403  
 2. LOCATION SW 1/4 NE 1/4 Sec. 28 T. 17 N/S R. 22 E Lyon County  
 PERMIT NO. 19-242-09 Mark Twain Estates Parcel No. Subdivision Name  
 Issued by Water Resources

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
sand & gravel		0	20	20 Ft
gravel & clay		20	60	40 Ft
gravel & Rock		60	100	40 Ft
clay & Rock		100	120	20 Ft
Rock & sand & gravel		120	145	25 Ft

94 JAN 25 AIO 32  
 RECEIVED  
 STATE ENGINEERS OFF.

8. WELL CONSTRUCTION  
 Depth Drilled 145 Feet Depth Cased 145 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From To  
10 5/8 Inches 0 Feet 145 Feet  
 Inches Feet Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>11</u>	<u>188</u>	<u>+1</u>	<u>145</u>

Perforations:  
 Type perforation factory milled  
 Size perforation 3/32 x 3  
 From 105 feet to 145 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 55 Ft  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 55 feet to 145 feet

9. WATER LEVEL  
 Static water level 68 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality clear

Date started Jan 15, 1994  
 Date completed Jan 18, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>20</u>		<u>1</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Enloe Drilling Co. Contractor  
 Address P.O. Box 1345 Dayton NV Contractor  
89403  
 Nevada contractor's license number issued by the State Contractor's Board 4739A  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1878  
 Signed Tom Enloe  
 By driller performing actual drilling on site or contractor  
 Date 1-17-94