

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 43599  
 Permit No. \_\_\_\_\_  
 Basin 6-85

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21804

1. OWNER Murray Nadell ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 16201 Hartsook St Pasa  
Encino, Ca 91436 Lot 55 Parcel D

2. LOCATION SW 1/4 NW 1/4 Sec. 18 T. 21 N/S R. 21 E. Washoe County  
 PERMIT NO. 76-360-55 - Spanish Springs

Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Overburden		0	2	2
D.G.		20	70	50
Soft to medium hard D.G.		70	120	50
Medium hard D.G.		120	130	10
Soft D.G.		130	210	80
D.G. & little clay		210	320	110
Medium to hard D.G. & granite		320	345	25
Hard granite		345	360	15
Medium hard to hard D.G. & granite		360	400	40
Granite		400	530	130
Granite & black volcanic rock		530	570	40
Granite & D.G.		570	596	26
T.D. 596 ft				

8. WELL CONSTRUCTION  
 Depth Drilled 596 Feet Depth Cased 596 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
10 5/8	0	56
8 1/2	56	596

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	+ 1	596

Perforations: factory

Type perforation \_\_\_\_\_  
 Size perforation 3/32 X 3

From 539 feet to 579 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type: \_\_\_\_\_  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured

Gravel Packed:  Yes  No  
 From 50 feet to 596 feet

9. WATER LEVEL  
 Static water level unknown feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cool °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Aqua Drilling & Well Service, Inc  
 Contractor  
 Address 625 Spice Islands Dr Suite L  
Sparks, Nv 89431  
 Contractor

Nevada contractor's license number 15291  
 issued by the State Contractor's Board

Nevada driller's license number issued by the 1804  
 Division of Water Resources, the on-site driller

Signed Roger M Thrall  
 By driller performing actual drilling on site or contractor  
 Date Roger M. Thrall 3/15/93

Date started 3/11/93, 19\_\_\_\_  
 Date completed 3/16/93, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
20		2