

OFFICE USE ONLY
 Log No. 43000
 Permit No. _____
 Basin. 7-93

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24985

1. OWNER Jim Stewart ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1128 La Via Way 1368 Antelope Valley Road
Sparks, Nevada 89434 Reno, Nevada
 2. LOCATION SW 1/4 SW 1/4 Sec. 23 T. 22 N/S R. 19 E Washoe County
 PERMIT NO. N/A 079-470-2297 Red Rock Estates #183 part 3
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED 4. PROPOSED USE 5. WELL TYPE
 New Well Replace Recondition Domestic Irrigation Test Cable Rotary RVC
 Deepen Abandon Other _____ Municipal/Industrial Monitor Stock Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Light brown sandy clay		0	48	48
" Gray clay		48	57	9
" Brown sand		57	63	6
" Gray clay		63	65	2
" " Sand	XX	65	72	7
" " Clay		72	98	26
" " Sand	XX	98	113	15
" " Clay		113	131	18
" " Sand	XX	131	145	14
" " Clay		145	150	5
" " Sand	XX	150	162	12
" " Clay		162	195	33
" " Sand	XX	195	197	2
" " Clay		197	200	3

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
9 7/8 Inches 0 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	-1	200

 Perforations:
 Type perforation Mill slot
 Size perforation 1/8 X 3
 From 120 feet to 140 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50+ Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 200 feet

Date started 12-17-93, 19_____
 Date completed 12-22-93, 19_____
 '94 JAN -3 P1 124
 STATE ENGINEERS

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
Approx.	20	190	2

9. WATER LEVEL
 Static water level 55 feet below land surface
 Artesian flow -0- G.P.M. -0- P.S.I.
 Water temperature COOL °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EMDLCO Contractor
 Address P.O. Box 8056 Contractor
Reno, Nevada 89507
 Nevada contractor's license number issued by the State Contractor's Board 32166
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418
 Signed Bruce Milley
 By driller performing actual drilling on site or contractor
 Date 12-22-93